

Important information About Your Drinking Water

Areas Include: Flynn's Creek Road

Jackson County UD #3 water System recently violated Federal Drinking water standards. Although this situation does not require that you take immediate action, you as a customer have a right to know what happened, what you should do, and what was done to correct this situation.

During the **October 1, 2025 through December 31, 2025**, compliance period, Jackson County UD #3 exceeded the Locational Running Average (LRAA) Maximum contaminant Levels (MCL) as indicated below.

Some people who drink water containing Trihalomethanes acids in excess of MCL over many years may have an increased risk of getting cancer. Some people who drink water containing trihalomethanes in excess of MCL over many years may experience problems with their liver, kidneys or central nervous systems, or may have an increased risk of getting cancer.

*During **October 1, 2025 through December 31, 2025**, compliance period the water system's Locational running Annual Average (LRAA) at site #101 George Green- Max PT, for Total Trihalomethanes (TTHM) has been calculated to be **0.08728 mg/l**. This value exceeds the Maximum Contaminant level of **0.080mg/l** set for this parameter.*

The actual risk has been identified as 1 out of 10,000 people may get cancer if they drink 2 liters of water each day for 70 years.

You do not need to boil your water or take other actions. However, if you have specific health concerns, consult your doctor.

Total Trihalomethanes are disinfection byproducts resulting from our chlorination of the water to minimize risk of microbial life in the drinking water. The **EPA** considers microbial contaminants as the greatest risk to the public. We are evaluating the results of the required disinfection and will continue trying to reduce the disinfection byproducts without increasing the microbial risks.

We are increasing our normal Flushing procedures to reduce the levels of the Halo acetic Acids and total Trihalomethanes.

For more information, please contact Brandon Holland at 931-268-2880

Please share this information with everyone who may drink this water, including those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by the JACKSON COUNTY UD #3, PWSID TN0000845. Date 2-6-2026