

Jackson County Utility District #4

2025 Consumer Confidence Report

Is my drinking water safe? Yes, our water meets all of EPA's health standards. We have conducted numerous tests for over 80 contaminants that may be in drinking water. As you'll see in the chart on the back, we only detected a few of these contaminants. We found all of these contaminants at safe levels.

What is the source of my water? Your water, which is ground water under direct influence of surface water, comes from Red Boiling Springs, which comes from the McClellan Springs and the Sabin Spring. Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water source to **potential** contamination.

The Tennessee Department of Environment and Conservation (TDEC) have prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving this water system. The SWAP Report assesses the susceptibility of untreated water sources to **potential** contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. The Jackson County Utility District sources rated as reasonably susceptible to potential contamination. An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <https://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html> or you may contact the Water System to obtain copies of specific assessments.

Why are there contaminants in my water? Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. Community water systems are required to disclose the detection of contaminants; however, bottled water companies are not required to comply with this regulation. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Is our water system meeting other rules that govern our operations? The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial,

or domestic wastewater discharges, oil and gas production, mining, or farming.

- Pesticides and herbicides, which may come from a variety of sources as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile

organic chemicals, which are by-products of industrial processes

and petroleum production, and can also come from gas stations,

urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas

production and mining activities.

In order to ensure that tap water is safe to drink, EPA and Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. For more information call EPA hot line at (800-426-4791).

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all of these requirements. Results of unregulated contaminant analysis are available upon request. We want you to know that we pay attention to all the rules.

Other Information Due to all water containing dissolved contaminants, occasionally your water may exhibit slight discoloration. We strive to maintain the standards to prevent this. We at Jackson County Utility District work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Do I Need To Take Special Precautions? Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Water System Security Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, pumping stations, tanks, fire hydrants, etc. to 268-2880.



Lead in Drinking Water If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

Pharmaceuticals In Drinking Water Flushing unused or expired medicines can be harmful to your drinking water. Learn more about disposing of unused medicines at <http://www.tnpharm.org/patient-resources/disposing-of-unwanted-drug/>

How can I get involved? If you have any questions or concerns, please call or come by our office. Our Board meets on the third Monday of each month at 7:00 p.m. at the utility office. Please feel free to participate in these meetings. If you have any items that you wish to address, please call the office at 268-2880 to be placed on the agenda.

For more information about your drinking water, please call Brandon Holland at the Utility District at 931- 268-2880 or come by our office between 8:00am to 4:00 pm, Monday – Friday, at 1478 N. Grundy Quarles Highway, Gainesboro, TN 38562

Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.

A cross connection is a connection between a drinking water pipe and a polluted source. The pollution can come from your own home. For instance, you're going to spray fertilizer on your

lawn. You hook up your hose to the sprayer that contains the fertilizer. If the water pressure drops (say because of fire hydrant use in the town) when the hose is connected to the fertilizer, the fertilizer may be sucked back into the drinking water pipes through the hose. Using an attachment on your hose called a backflow-prevention device can prevent this problem. The Jackson County Utility District recommends the installation of backflow prevention devices, such as a low cost hose bib vacuum breaker, for all inside and outside hose connections. You can purchase this at a hardware store or plumbing supply store. This is a great way for you to help protect the water in your home as well as the drinking water system in your town! For additional information on cross connections and on the status of your water system's cross connection program contact our office.

Selection of the Jackson County Utility Board Members. The Commissioners of The Jackson County Utility District serve four-year terms. Vacancies on the Board are filled by appointment by the Jackson County Mayor from a list of three nominees certified by the Board of Commissioners to the Jackson County Mayor to fill a vacancy. Decisions by the Board on customer complaints brought before the Board of Commissioners under the District's customer complaint policy may be reviewed by the Utility Management Review Board of Tennessee Department of Environment and Conservation Pursuant to Section 7-82-702(7) Of Tennessee code annotated.

"In accordance with the Federal law and the U.S. Department of Agriculture policy, this institution is prohibited from discrimination on the basis of race, color, national origin, sex, age, or disability. (Not all prohibited bases apply to all programs). To file a complaint of discrimination, write USDA, Director, Office of Civil Rights, 1400 Independence Avenue., S.W., Washington, D.C. 20250-9410, or call (800) 795-3272 (voice), or (202) 720-6382 (TDD)."

2025 Water Quality Data (JCUD#4 PWSID#0000859)

What does this chart mean?

- **MCLG** - Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL** - Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- **MRDL**: Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- **MRDLG**: Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **AL** - Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. Non-Detects (ND) - laboratory analysis indicates that the contaminant is not present.
- **Parts per million (ppm) or Milligrams per liter (mg/l)** – explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion (ppb) or Micrograms per liter** - explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Nephelometric Turbidity Unit (NTU)** - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **TT** - Treatment Technique or a required process intended to reduce the level of a contaminant in drinking water.

Contaminant	Violation Yes/No	Level Detected	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria	NO	0		2025		0	<2 positive samples	Naturally present in the environment
Turbidity ¹	NO	.28 EP-A .02 EP-C	.02-.28 NTU	2025	NTU	N/A	TT	Soil runoff
Copper	NO	90 th % = .928	.00131- .00983	2025	ppm	1.3	AL=1.3	Corrosion of household plumbing systems
Lead ²	NO	90 th % = 1.0	.1.0-1.0	2025	ppb	0	AL=15	Corrosion of household plumbing systems
Sodium	NO	5.84 EP-A 3.79 EP-C		2025	ppm	N/A	N/A	Erosion of natural deposits; used in water treatment
TTHM [Total trihalomethanes]	NO	23.2	19.0-29.2	2025	ppb	N/A	80	By-product of drinking water chlorination
Haloacetic Acids (HAAs)	NO	13.6	9.17-19.0	2025	ppb	N/A	60	By-product of drinking water disinfection.
Total Organic Carbon ³	NO			2025	ppm	TT	TT	Naturally present in the environment.
Chlorine	NO	1.65 AVG.	1.1-2.0	2025	ppm	4	4	Water additive used to control microbes.
Nitrate	NO	1.71 EP-A .863 EP-C		2025	ppm	10ppm	10ppm	Runoff from fertilizer use

1 Turbidity does not present any risk to your health. Turbidity is the measure of the cloudiness of water. Our levels were below .3 NTU.

2 During the most recent round of lead and copper testing, only 0 out of 10 households sampled contained concentrations exceeding the action level.

3 We meet the treatment technique for Total Organic Carbon.

During the 2024 sampling period we had 2 sample locations that exceeded the action level exceedance.

The first site was 1746 Wartrace Hwy with a 1.31 mg/l level, and the second being 190 Holland Cem Ln. with a 1.45 mg/l level.

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.